


PREVIEW OF RESULTS

Client: DYNAMOBEL
Date of test: 24th of February, 2016
Complete results are available to the client



Test carried out by
LGAI Technological Center S.A.

Measurement of airborne sound insulation according to EN ISO 10140-2



Frequency Hz	R
100	21,6
125	25,8
160	30,5
200	31,6
250	34,9
315	36,4
400	35,5
500	35,6
630	37,1
800	37,6
1000	37,5
1250	35,5
1600	34,6
2000	35,7
2500	32,3
3150	32,8
4000	36,1
5000	38,7

Test element description:

METALLIC BLIND 90 DOOR



WEIGHTED SOUND REDUCTION INDEX, R_w (C; C_{tr})

36 (-1; -2) dB