


PREVIEW OF RESULTS

Client: DYNAMOBEL
Date of test: 24th of February, 2016
Complete results are available to the client



Test carried out by
LGAI Technological Center S.A.

Measurement of airborne sound insulation according to EN ISO 10140-2



Frequency Hz	R
100	15,2
125	23,4
160	34,9
200	35,0
250	33,2
315	33,8
400	34,9
500	36,5
630	36,6
800	36,4
1000	36,2
1250	34,2
1600	33,5
2000	34,7
2500	32,8
3150	31,1
4000	34,1
5000	38,0

Test element description:

BLIND 90 DOOR



WEIGHTED SOUND REDUCTION INDEX, $R_w(C; C_{tr})$

35 (-2; -3) dB